



NOTES:
 1. ACTUATOR SHOWN IN COUNTER CLOCKWISE EXTREME OF TRAVEL OR 'OPEN' POSITION

OPERATION:
 1. DC SUPPLY VOLTAGE AT TERMINAL #'S 13 & 14. 4 AMPS MINIMUM
 2. DC SUPPLY VOLTAGE AT TERMINAL #'S 13 & 14 AND CONTACT CLOSURE AT TERMINAL #'S 15 & 16 = VALVE OPEN (CCW)
 3. DC SUPPLY VOLTAGE AT TERMINAL #'S 13 & 14 AND OPEN CONTACTS AT TERMINAL #'S 15 & 16 = VALVE CLOSED (CW)

* RY1 = DC DPDT RELAY

THIS DRAWING AND ALL INFORMATION HEREON IS THE PROPERTY OF ASAHI/AMERICA. ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE IS FORBIDDEN WITHOUT WRITTEN CONSENT.

ASAHI/AMERICA
 ISO 9001 CERTIFIED
 35 GREEN STREET, P.O. BOX 653, MALDEN, MA.



WIRING DIAGRAM FOR
 SERIES 92/94 12/24VDC
 WITH TWO-WIRE CONTROL

| DR | NAME | DATE |
|------------|------------|---------|
| JGLASSFDRD | | 9/26/08 |
| APPD | K.BLYSTONE | 9/26/08 |
| PROD | | |
| WO#/SO# | | |
| FILE | | |

| | | | |
|-------|-----|----------|----------|
| SCALE | NTS | SHEET 1 | OF 1 |
| SIZE | A | DWG. NO. | M18EL761 |
| REV | A | | |